

# 2018 Consumer Confidence Report

Water System Name: Palo Verde Union School System #5400519 Report Date: May 31, 2019

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.*

**Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Palo Verde Union School a (559) 688-0648 para asistirlo en español.**

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系 Palo Verde Union School, 获得中文的帮助:  
9637 Avenue 196, Tulare, CA (559) 688-0648.

**Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Palo Verde Union School; 9637 Avenue 196, Tulare, CA o tumawag sa (559) 688-0648 para matulungan sa wikang Tagalog.**

**Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Palo Verde Union School tại (559) 688-0648 để được hỗ trợ giúp bằng tiếng Việt.**

**Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Palo Verde Union School ntawm (559) 688-0648 rau kev pab hauv lus Askiv.**

Type of water source(s) in use: Groundwater Well

Name & location of source(s): Well 001 sits in the center north area of the school grounds, 75 yards west of the bus garage at 9637 Ave 196 Tulare, CA 93247

Drinking Water Source Assessment information: Available by appointment or by contacting Tulare County Department of Environmental Health – Drinking Water Division

Time and place of regularly scheduled board meetings for public participation: Second Tuesday of every month in the staff lounge.

For more information, contact: Phil Anderson Phone: (559) 688-0648

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential

<p>contaminants.</p> <p><b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p> <p><b>Primary Drinking Water Standards (PDWS):</b> MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p>	<p>problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.</p> <p><b>ND:</b> not detectable at testing limit</p> <p><b>ppm:</b> parts per million or milligrams per liter (mg/L)</p> <p><b>ppb:</b> parts per billion or micrograms per liter (µg/L)</p> <p><b>ppt:</b> parts per trillion or nanograms per liter (ng/L)</p> <p><b>ppq:</b> parts per quadrillion or picogram per liter (pg/L)</p> <p><b>pCi/L:</b> picocuries per liter (a measure of radiation)</p>
---	---

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) 6/29/17	5	3.85	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 6/29/17	5	0.095	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7/14/08	92.6	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	7/14/08	36.2	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

\*Any violation of an MC or AL is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<b>Inorganic Contaminants</b>						
Aluminum (ppm)	7/11/17	0.12	N/A	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (ppb)	7/11/17	7.6	N/A	10	0.004	Erosion of natural deposits; runoff from orchards, from glass and electronics production waste
Chromium (ppb)	7/11/17	14	N/A	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	7/11/17	0.2	N/A	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead (ppb)	7/11/17	1.0	N/A	AL = 15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Nitrate (as nitrogen) (ppm)	7/19/18	3.6	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
<b>Radioactive Contaminants</b>						
Gross Alpha Particle Activity (pCi/L)	10/16/17	9.06	N/A	15	(0)	Erosion of natural deposits
Uranium (pCi/L)	10/16/17	7.6	N/A	20	0.43	Erosion of natural deposits

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Total Radium 228 (pCi/L)	11/14/11	0.505	N/A	2	0.019	Erosion of natural deposits
Total Radium (pCi/L)	2/1/18 – 5/6/18	0.21	N/A	5	n/a	Erosion of natural deposits
Synthetic Organic Contaminants including Pesticides and Herbicides						
Di(2-ethylhexyl) phthalate (DEHP) (ppb)	1/17/08	5.3	N/A	4	12	Discharge from rubber and chemical factories; inert ingredient in pesticides

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppb)	7/11/17	119	N/A	200	none	Erosion of natural deposits; residual from some surface water treatment processes
Iron (ppb)	7/14/08	296	N/A	300	none	Leaching from natural deposits; industrial wastes
Zinc (ppm)	7/14/08	0.13	N/A	5.0	none	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS) (ppm)	7/14/08	280	N/A	1000	none	Runoff/leaching from natural deposits
(EC) (umhos/cm) Specific Conductance $\mu$ S/cm	7/14/08	507	N/A	1600	none	Substances that form ions when in water; seawater influence
Chloride (ppm)	7/14/08	53.5	N/A	500	none	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	7/14/08	42.6	N/A	500	none	Runoff/leaching from natural deposits; industrial wastes
Turbidity (Units)	7/17/08	0.5	N/A	5	none	Soil runoff
Color (Units)	7/17/08	5	N/A	15	none	Naturally-occurring organic materials
Odor-Threshold (Units)	7/17/08	1	N/A	3	none	Naturally-occurring organic materials

There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.

**TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Hexavalent Chromium (ppb)	12/16/14	0.78	N/A	n/a	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits

*\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

*The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old*

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Arsenic:** While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**di(2-ethylhexyl) phthalate:** Some people who use water containing di(2-ethylhexyl) phthalate in excess of the MCL over many years may experience liver problems or reproductive difficulties, and may have an increased risk of getting cancer.

**Gross Alpha Particle:** Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

## Summary Information for Contaminants Exceeding an MCL, MRDL, or AL or Violation of Any TT or Monitoring and Reporting Requirement

No Violations

## 2018 ANNUAL WATER ANALYSES SUMMARY

The following water quality information is provided annually.

For further water system information or to inquire about the most recent water quality information available, please contact manager.

### MICROBIOLOGICAL QUALITY

Minimum number of tests required per year is 12.

Number of water samples tested for the presence of coliform bacteria during the year is 12.

Number of samples tested which failed to meet the microbiological drinking standard during the year is 0.

Sampling results showing the detection of coliform bacteria			
	Highest No. of Detections	No. of months in violation	MCL
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>
<i>E. coli</i> (Federal Revised Total Coliform Rule)	(In the year) 0	0	(a)

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

### INORGANIC CHEMICAL QUALITY

Results of water samples analyses done to determine the presence or absence of inorganic chemical contamination. All values expressed in milligrams per liter (mg/l) unless otherwise indicated. Milligrams per liter are equivalent to parts per million (ppm). The symbol "<" means less than. The symbol "ND" means not detected.

<u>Inorganic Chemical</u>	California	California	PHGs <sup>2</sup>	MCLGs <sup>3</sup>	Level	Level	Date
	MCL <sup>1</sup>	MCL <sup>1</sup>			Detected	Detected	
	(mg/l)	(ug/l)	(ppb)	(mg/l)	(mg/l)	(ug/l)	Sampled
Sys # 5400519-001							
Well 1							
Aluminum (Al)	0.2	200	N/A	N/A	0.12	119	07/11/17
Antimony (Sb)	0.006	6	20			<2.0	07/11/17
Arsenic (As)	0.01	10	N/A	0		7.6	07/11/17
Barium (Ba)	1.0	1000	N/A	2	<0.1	<100.	07/11/17
Beryllium (Be)	0.004	4	N/A	0.004	<0.001	<1	07/11/17
Cadmium (Cd)	0.005	5	N/A	0.005	<0.001	<1	07/11/17
Chromium (Cr)	0.05	50	N/A	0.1	0.01	14	07/11/17
Fluoride (F)	2.0				0.2		07/11/17
Lead (Pb)		AL=15	N/A	0.002		1.0	07/11/17
Mercury (inorganic) (Hg)	0.002	2	N/A	0.1		<0.20	07/11/17
Nickel (Ni)	0.10	100	N/A	0.05	<0.01	<10	07/11/17
Selenium (Se)	0.05	50				<2.0	07/11/17
Silver (Ag)	0.10	100	N/A	0.0005	<0.01	<10	07/11/17
Thallium (Tl)	0.002	2	1000			<1.0	07/11/17
Nitrate (as nitrogen, N) (NO <sub>3</sub> -N)	10		10000 as N		3.6		07/19/18
Nitrite (as nitrogen, N) (NO <sub>2</sub> -N)	3		10000 as N		<0.4	<400	07/11/17

AL = Action Level

**Inorganic Analysis**

(EPA Method 218.6)

Hexavalent Chromium N/A 0.78 12/16/14

**GENERAL MINERAL QUALITY TEST RESULTS**

<u>Constituents</u>	California	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Level	Date Sampled
	MCL <sup>1</sup> (mg/l)	MCL <sup>1</sup> (ug/l)			Detected (mg/l)	Detected (ug/l)	
Sys # 5400519-001							
Well 1							
pH					8.4		07/14/08
Total Alkalinity as CaCO <sub>3</sub>					152		07/14/08
Hydroxide (OH)					<1		07/14/08
Carbonate (CO <sub>3</sub> )					3.0		07/14/08
Bicarbonate (HCO <sub>3</sub> )					149		07/14/08
Calcium (Ca)					12.1		07/14/08
Copper (Cu)	1.0	1000	170		<0.01	<10	07/14/08
Iron (Fe)	0.3	300	1000		0.30	296	07/14/08
Magnesium (Mg)					1.5		07/14/08
Manganese (Mn)	0.05	50			<0.01	<10	07/14/08
Sodium (Na)					92.6		07/14/08
Zinc (Zn)	5.0	5000			0.13	129	07/14/08
Total Hardness as CaCO <sub>3</sub>					36.2		07/14/08
Langlier Index (LI)					0.27		07/14/08
Foaming Agents (MBAS)	0.5	500			<0.1		07/14/08

<u>Constituent, Units</u>	<u>Recommended</u>	MCL	MCL	Level	Date	
		<u>Upper</u>	<u>Short Term</u>	<u>Detected</u> (mg/l)	<u>Sampled</u>	
Sys # 5400519-001						
Well 1						
Total Dissolved Solids (TDS), mg/l		500	1000	1600	280	07/14/08
Specific Conductance (EC), micromhos/cm		900-2200	1600	2200	507	07/14/08
Chloride (Cl), mg/l		250	500	600	53.5	07/14/08
Sulfate (SO <sub>4</sub> ), mg/l		250	500	600	42.6	07/14/08

**GENERAL PHYSICAL QUALITY TEST RESULTS**

<u>Constituents</u>	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date
	MCL <sup>1</sup> (mg/l)			Detected units	Sampled
Sys # 5400519-001					
Well 1					
Turbidity	5 units			0.5	07/17/08
Color	15 units			5.0	07/17/08
Odor-Threshold at 60°C	3 units			1.0	07/17/08

**ORGANIC CHEMICAL QUALITY**

Results of water sample analyses done to determine the presence of organic chemical contamination in the water supply.

Names and concentrations of any organic contaminants including pesticides, herbicides and other organic chemicals detected in the water supply source.

Organic Chemical Method: EPA .525.2	California	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date
		MCL <sup>1</sup> (ug/l)			Detected (ug/l)	Sampled
Sys # 5400519-001 Well 1						
Molinate (ORDRAM)		NA	NA		<0.50	07/10/18
Simazine (PRINCEP)		NA	0.004		<0.30	07/10/18
Thiobencarb (BOLERO)		NA	NA		<0.50	07/10/18
Alachlor (ALANEX)		2			<0.20	07/10/18
Bromacil (HYVAR)		NA	NA	NA	<0.50	07/10/18
Butachlor					<0.30	07/10/18
Diazinon					<0.20	07/10/18
Metribuzin		NA			<0.50	07/10/18
Prometryn (Caparol)		NA			<0.50	07/10/18
Metolachlor		NA			<0.50	07/10/18
Dimethoate (CYGON)		NA			<2.0	07/10/18
Atrazine (AATREX)			0.003		<0.30	07/10/18
Atraton					<0.50	07/10/18
Propachlor					<0.50	07/10/18
Prometon					<0.50	07/10/18
Secbumeton					<0.50	07/10/18
Terbutryn					<0.50	07/10/18

Volatile Organic Analysis(VOC) (EPA Method 524.2 ) <u>Constituents</u>	California	California	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)	Level	Date	
		MCL <sup>1</sup> (mg/l)			Detected (ug/l)	Sampled	
Sys # 5400519-001 Well 1							
Total Trihalomethanes (THM'S/TTHM)			80	N/A	N/A	<2.0	10/07/14
Bromodichloromethane						<0.50	10/07/14
Bromoform						<0.50	10/07/14
Chloroform (Trichloromethane)						<0.50	10/07/14
Dibromochloromethane						<0.50	10/07/14
Benzene		0.001	1	0.15		<0.50	10/07/14
Carbon Tetrachloride		0.0005	0.5	0.1		<0.50	10/07/14
1,2 Dichlorobenzene (o-DCB)		0.6	600	660		<0.50	10/07/14
1,4-Dichlorobenzene (p-DCB)		0.005	5	6		<0.50	10/07/14
1,1-Dichloroethane (1,1-DCA)		0.005	5	3		<0.50	10/07/14
1,2-Dichloroethane (1,2-DCA)		0.0005	0.5	0.4		<0.50	10/07/14
1,1-Dichloroethylene (1,1-DCE)		0.006	6	10		<0.50	10/07/14
cis-1,2-Dichloroethylene (c-1,2-DCE)		0.006	6	100		<0.50	10/07/14
trans-1,2-Dichloroethylene (t-1,2-DCE)		0.01	10	60		<0.50	10/07/14
Dichloromethane (Methylene Chloride)		0.005	5	4		<0.50	10/07/14
1,2-Dichloropropane		0.005	5			<0.50	10/07/14
Total 1,3-Dichloropropene		0.0005	0.5	0.2		<0.50	10/07/14
Ethyl Benzene		0.3	300	300		<0.50	10/07/14
Methyl tert-Butyl Ether (MTBE)		0.013	13	13		<0.50	10/07/14
Monochlorobenzene (Chlorobenzene)		0.07	70	200		<0.50	10/07/14
Styrene		0.1	100	100	0.1	<0.50	10/07/14
1,1,2,2-Tetrachloroethane		0.001	1	0.1		<0.50	10/07/14
Tetrachloroethylene (PCE)		0.005	5	0.06	0	<0.50	10/07/14
Toluene		0.15	150	150		<0.50	10/07/14



**Volatile Organic Analysis(VOC)(Cont.)  
(EPA Method 524.2)  
Constituents**

Constituents	California				Level Detected (ug/l)	Date Sampled
	MCL <sup>1</sup> (mg/l)	MCL <sup>1</sup> (ug/l)	PHGs <sup>2</sup> (ppb)	MCLGs <sup>3</sup> (mg/l)		
1,2,4-Trichlorobenzene	0.01	5	5		<0.50	10/07/14
1,1,1-Trichloroethane (1,1,1-TCA)	0.2	200	1000	0	<0.50	10/07/14
1,1,2-Trichloroethane (1,1,2-TCA)	0.005	5	0.3		<0.50	10/07/14
Trichloroethylene (TCE)	0.005	5	0.8	0	<0.50	10/07/14
Trichlorofluoromethane (Freon 11)	0.15	150	700		<0.50	10/07/14
Trichlorotrifluoroethane (Freon 113)	1.2	1200	4000		<0.50	10/07/14
Vinyl Chloride (VC)	0.0005	0.5	0.05	0	<0.50	10/07/14
m,p,-Xylene					<0.50	10/13/08
o-Xylene					<0.50	10/13/08
Total Xylenes (m,p, & o)	1.75	1750	1800		<1.0	10/07/14
Dibromochloropropane (DBCP)	0.0002	0.2			<1.0	10/13/08
tert-Amyl Methyl Ether (TAME)	N/A				<.50	10/07/14
Bromobenzene	N/A				<0.50	10/07/14
Bromochloromethane	N/A				<0.50	10/07/14
Bromomethane (Methyl Bromide)	N/A				<1.0	10/07/14
tert-Butyl Alcohol (TBA)					<10	10/07/14
n-Butylbenzene	N/A				<0.50	10/07/14
sec-Butylbenzene	N/A				<0.50	10/07/14
tert-Butylbenzene	N/A				<0.50	10/07/14
Chloroethane	N/A				<0.50	10/07/14
Chloromethane (Methyl Chloride)	N/A				<0.50	10/07/14
2-Chlorotoluene	N/A				<0.50	10/07/14
4-Chlorotoluene	N/A				<0.50	10/07/14
Dibromomethane	N/A				<0.50	10/07/14
1,3-Dichlorobenzene (m-DCB)					<0.50	10/07/14
Dichlorodifluoromethane (Freon 12)	0.0005	5	N/A	N/A	<0.50	10/07/14
1,3-Dichloropropane					<.50	10/07/14
2,2-Dichloropropane	N/A				<.50	10/07/14
1,1-Dichloropropene	N/A				<.50	10/07/14
Ethyl tert-Butyl Ether (ETBE)	N/A				<.50	10/07/14
Hexachlorobutadiene	N/A				<.50	10/07/14
Isopropylbenzene (Cumene)	N/A				<.50	10/07/14
p-Isopropyltoluene	N/A				<.50	10/07/14
Naphthalene	N/A				<.50	10/07/14
n-Propylbenzene	N/A				<.50	10/07/14
1,1,1,2-Tetrachloroethane	N/A				<.50	10/07/14
1,2,3-Trichlorobenzene	N/A				<.50	10/07/14
1,2,3-Trichloropropane	N/A				<1.0	10/07/14
1,2,4-Trimethylbenzene	N/A				<.50	10/07/14
1,3,5-Trimethylbenzene					<.50	10/07/14
cis-1,3-Dichloropropene (D-D)	0.0005	0.5			<.50	10/13/08
trans-1,3-Dichloropropene	0.0005	0.5			<.50	10/13/08

	MCL (ug/l)	Level Detected (ug/l) <u>Well 01</u>	Date Sampled
1,2,3-Trichloropropane [TCP]	0.005	<0.0050	02/07/18
1,2,3-Trichloropropane [TCP]	0.005	<0.0050	05/07/18
1,2,3-Trichloropropane [TCP]	0.005	<0.0050	08/06/18
1,2,3-Trichloropropane [TCP]	0.005	<0.0050	11/06/18

EPA Method 504.1	California			Level	
	MCL <sup>1</sup> (ug/l)	PHGs <sup>2</sup> (ug/l)	MCLGs <sup>3</sup> (ug/l)	Detected (ug/l)	Date Sampled
Dibromochloropropane (DBCP)	0.2	N/A	0.0017	ND	07/11/17
Ethylenedibromide (EDB)	0.05	N/A	0.01	ND	07/11/17

**RADIOLOGICAL QUALITY**

Parameter	Max. Level Allowed (in pCi/l)	Level	
		Detected (in pCi/l)	Date Sampled
Sys # 5400519-001 Well 1			
Gross Alpha	15	9.06	10/16/17
Uranium	20	7.6	10/16/17
Total Radium - Radium 226 + Radium 228 combined	5	0.29	02/07/18
Total Radium - Radium 226 + Radium 228 combined	5	ND	05/07/18
Total Radium - Radium 226 + Radium 228 combined	5	0.328	05/06/18
Average		0.21	

Method EPA 314 Parameter	Max. Level Allowed (ug/l)	Level	
		Detected (ug/l)	Date Sampled
Sys # 5400519-001 Well 1			
Perchlorate	6	<4.0	07/11/17

**LEAD AND COPPER ANALYSIS**

Constituent	Lead (Pb) Action Level (AL) 15 ug/l			Method: EPA-200.8	
	Copper (Cu) Action Level (AL) 1.3 mg/l			Method: EPA-200.8	
Client Sample ID	Copper (mg/l)	Copper (ug/l)	Lead (ug/l)	Date Sampled	
Staff Room	0.031	31	ND	6/29/17	enter 2 highest values for lead and copper
Rm 401	0.005	4.6	ND	6/29/17	
Office	0.160	160	ND	6/29/17	Copper
Bus Barn	0.013	13	1.1	6/29/17	Lead
Maint Shop	0.004	3.6	6.6	6/29/17	(mg/l)
					(ug/l)
					0.03
					1.1
					0.16
					6.6
				90th percentile->	0.095
					3.85

- <sup>1</sup>MCL            Maximum Contaminant Level
- <sup>2</sup>PHGs        Public Health Goals
- <sup>3</sup>MCLGs      Maximum Contaminant Level Goals (Federal)

Please call if you have any questions. (559) 233-6129

Sincerely,



Keith M. Backman,  
Dellavalle Laboratory, Inc.